



ELECTRIC STAKING SHEET LEGEND

- Proposed primary mainline electric distribution line, 4/0 AL., 3Ø in (3)2" ducts.
- Proposed primary subloop electric distribution line, 1/0 AL., 3Ø in (3)2" ducts.
- Proposed primary subloop electric distribution line, 1/0 AL., 2Ø in (2)2" ducts.
- Proposed primary subloop electric distribution line, 1/0 AL., 1Ø in (1)2" ducts.
- Existing primary underground electric distribution line
Hashes indicate number of phases
- Existing primary overhead electric distribution line
Hashes indicate number of phases
- Proposed service cable, 4/0 TPLX. in (1)2" duct.
- Proposed secondary cable, 350 TPLX. in (1)2.5" duct.
- Proposed street light cable, 10-2 UF. in (1)1" duct.
- Proposed service cable, 4/0 QUAD. direct buried. U.O.N.
- Existing secondary, service or street light cable
- Existing sectionalizing pedestal, 3Ø
- Proposed sectionalizing pedestal, 3Ø
- Existing sectionalizing pedestal, 1Ø
- Proposed sectionalizing pedestal, 1Ø
- Existing pad mount transformer, 1Ø
- Proposed pad mount transformer, 1Ø, w/kVA rating
- Existing pad mount transformer, 3Ø
- Proposed pad mount transformer, 3Ø, w/kVA rating
- Existing overhead transformer, 1Ø
- Proposed secondary pedestal
- Proposed street light location
- Existing meter location
- Stake number
- Proposed cable splice
- Proposed fault indicator
- Proposed normally open point
- Proposed padmount switchgear
+ = switch bay
S = fuse bay
- Proposed Primary Riser



REV	DATE	DESCRIPTION
A	03-06-2020	RELEASED FOR OWNER'S REVIEW
B	03-13-2020	REVISED PER OWNER COMMENTS
C	03-16-2020	RELEASED FOR CONSTRUCTION



Project Manager: TWM
 Designer: DSM
 Project Number: 425400
 Phone: (712) 472-2531

BRECKENRIDGE PUBLIC UTILITIES,
 BRECKENRIDGE, MINNESOTA

KEYMAP
 STAKING SHEETS
 DISTRIBUTION IMPROVEMENTS - TWITO FEEDER A

S
H
E
E
T
 1 OF 1